







Date Released: **05-17-12**

Tracking Number: **IGACFS-001**

Installation Guide – AC Freeze Sensor

	
<p>1. Before template installation and with upper unit placed over opening, the freeze sensor should be installed in the evaporator coil.</p>	<p>2. Remove the sensor from parts bag.</p>
	
<p>3. Using a flat screw driver, create a ¼” gap between 2 fins to accept the sensor (this should be located between the 2nd and 3rd tubes).</p>	<p>4. Slowly press the retainer clip and sensor into the gap created in Step 3 until the retainer clip locks onto the 3rd coil.</p>
	 <div data-bbox="1393 1518 1565 1623" style="border: 1px solid red; padding: 2px;"> <p>Sensor connector</p> </div>
<p>5. Install the template and electrical box on the ceiling.</p>	<p>6. Connect the sensor wires.</p>

Caution:

- 1.** Make sure the retainer clip is secured to the copper tube.
- 2.** Don't pull on the sensor wire as damage may occur.